

MDI/CCP/JUF&F/HOSTEL-2/2026-27 dated: 29.04.2026

CORRIGENDUM-1

“PROVIDING & FIXING OF JOINERY UNITS, INTERIOR FURNISHING & FINISHING FOR THE PROPOSED CONSTRUCTION WORKS OF HOSTEL-2 (BOYS HOSTEL) AT MDI CAMPUS, GURUGURAM, HARYANA”

With reference to the Tender published by MDI, Gurgaon on 29 April 2026, the following Corrigendum is issued.

Sl. No.	Existing Description/Pre-Bid Query	clarification
1	BoQ item number-5: - Structural steel work in single section, fixed with or without connecting plate, including cutting, hoisting, fixing in position and applying a priming coat of approved steel primer all complete.	Tubular section to be taken
2	BoQ Item number 11: - Providing and fixing shower cubicle of approved make and design, comprising 8 mm thick toughened safety glass panels, as shown in drawing, fixed with SS 304 grade hardware including wall channels, hinges, handles, clamps, brackets, and magnetic strip, complete. The cubicle shall be fixed over finished floor and wall surfaces, including necessary drilling, anchoring, sealing with clear silicone sealant, and making watertight joints, complete in all respects as per approved drawings, specifications, manufacturer's instructions, and direction of Engineer-in-Charge.	Size of Shower Cubicle- 1500(W) mm X 2100(H) mm Including door.

The other terms and conditions mentioned in the Tender document will remain the same.



Chief Administrative Officer (Admin)
MDI Gurgaon