

## MDI-Campus Development & Rejuvenation

### Sub:- Clarifications to the points raised in the Pre-Bid meeting held on 20<sup>th</sup> May, 2024

In continuation to the tender for the Supply Installation, Testing commissioning (SITC) of Lifts in proposed building at MDI Gurgaon, published in 14<sup>th</sup> May,2024, the queries raised during the Pre-Bid meeting held on 20<sup>th</sup> May,2024 is further clarified on the basis of tender published by MDI, Gurgaon.

Details	Description as per tender	Clarifications
Page no 70 para 20	Operating buttons and indications in the car	It is standard practice that touch panel buttons are inclusive of braille button or it is to be provided
Page no 69 para 16	Brushed SS+Shaker Heights Cherry	Brushed SS or equivalent finish are accepted
Page no 100 lift shaft	Academic block Sr. No.3- 2000mm x 2000mm shaft size & Door Size 1000mm x 2400mm	The door size from 900 mm x 2400mm to 1000mm x 2400mm can be considered.
<b>Academic block</b>		
BOQ item no.1 page no 70 point no 18	Landing Entrance -outer side- 17 doors	It is provided in tender, please refer SOW-Phase-1 sheet page no 100
BOQ item no. 02 page no -74 point no-18	Landing Entrance -outer side- 17 doors	
BOQ item no -3 Page No-79 Point- 18	Landing Entrance- outer side- 17 doors	
<b>Hostel Block</b>		
BOQ Item no.1 page no -85 point no- 18	Landing Entrance- outer side -17 doors	It is provided in tender, please refer SOW-Phase-1 sheet page no 100
BOQ item no.02 Page no-90 Point no-18	Landing Entrance- outer side -17 doors	

Date:29/05/2024



(Arun Kumar Singh)  
 Chief Administrative Officer  
 MDI-Gurgaon